



Water Pollution Control Facility

# Permit & Performance Data

|         | Performance     |                 | Effluent Permit Limits                    |
|---------|-----------------|-----------------|---|
|         | Influent (mg/L) | Effluent (mg/L) |   |
| BOD     | 150 – 250       | 5               | 45 mg/L weekly average                    |
| TSS     | 200 -250        | 3               | 30 mg/L monthly average                   |
| pH      | 7.2             | 7.0             | 6.0 – 9.0 s.u.                            |
| TRC     |                 | 0.3 – 0.5       | 1.0 mg/L                                  |
| E.Coli  |                 | 0 – 20/100 ml   | 426/100 ml daily max<br>64/100 ml monthly |
| Average |                 |                 |   |
| PO4     | 5.1             | 1.0             | Report                                    |
| NH3     |                 | 0.57            | Report                                    |