

Certificate of Occupancy Checklist-(Residential)

Address:		
Conta	ct Person:	
Phone	e Number:	
Email:		
Gener	ral Inspection Checklist	
	Doors/Windows: Pass/ Fail Doors and windows must be in good repair and in working condition. Two means of egress will be provided.	
	Fall protection from windows: Pass/ Fail Windows and any exterior opening on a second floor and higher that creates a hazard and/or window sills that are less than 24 inches from the floor must have proper fall protection.	
	Interior Stairs/Rail: Pass/ Fail Stairs shall have "graspable" handrails if serving 4 or more risers	
	Ceilings/Floors: Pass/ Fail All interior surfaces shall be maintained in good, clean and sanitary condition. Peeling, chipping, flaking or abraded paint shall be repaired, removed or covered.	
	Sanitary Toilets/Sinks: Pass/Fail Plumbing fixtures and drains must be in working condition, no leaks. Bathrooms vented.	
	Smoke and Carbon Monoxide Detectors: Pass/Fail Hard wired interconnected combination smoke and carbon monoxide detectors shall be located on all levels of the building.	
	Carbon Monoxide Detector: Pass/Fail Carbon Monoxide detectors are required outside of sleeping room in common hallway.	
	Clothes Dryer Vented: Pass/ Fail Dryers shall have metal UL listed non-combustible exhaust ducts and be vented to exterior.	

Kitchen Exhaust Fan: Pass/ Fail Has a kitchen exhaust fan been installed over the cook stove?
Locking Devices on Doors: Pass/ Fail Doors with deadbolts shall have the "thumb latch" style control.
GFI Receptacles: Pass/ Fail GFCI receptacles required if within 6ft of bathroom sink, along kitchen countertops, garages, basement, and outside
Sump Pump: Pass/ Fail Sump Pumps shall not discharge into the sanitary sewer.
Hammer arrestor devices: Pass/ Fail Hammer arrestor devices need to be installed for the dishwasher and washing machine.
House number: Pass/ Fail Numbers and letters shall be white reflective with black reflective background and a white reflective trim. Font shall not be cursive. Numbers for a single family shall be (4) inches tall on (6) inch background. Background width shall be no less than (8) inches.
Exterior Structure: Pass/ Fail The exterior of a structure shall be maintained in good repair, structurally sound and sanitary.
Exterior Stairs/Handrails: Pass/ Fail Stairs shall have "graspable" handrails if serving 4 or more risers.
Gutters & Downspouts: Pass/Fail Roof drains, gutters and downspouts shall be maintained in good repair. Roof water shall not be discharged directly on to a neighboring property.
Curbs, Sidewalks, & Driveway: Pass/ Fail Curbs, sidewalks, and driveways shall be in good repair, free from cracks and voids.
Weeds & Overgrowth: Pass/ Fail Property shall be maintained free of trash, weeds and overgrowth.
Garage/Outbuildings: Pass/ Fail All accessory structures, including detached garages, fences and walls, shall be maintained structurally sound and in good repair.
Trash/Debris/Combustibles: Pass/ Fail All exterior property and premises shall be free from any accumulation of trash or debris.

40 F NA

Ш	All plumbing fixtures shall be properly installed and maintained in working order; a back siphonage device or double check valve is required to be installed on the system.
	Water System: Pass/ Fail Every plumbing fixture shall be properly connected to a water system and shall be supplied with hot and cold running water; for water heaters a pressure relief valve and relief valve discharge pipe shall be properly installed and maintained.
	Electrical Facilities: Pass/ Fail All electrical equipment, wiring and appliances shall be properly installed and maintained in a safe and approved manner. Panels will be labeled and not blocked, no exposed wiring, covers must be on outlet boxes No extension cords used as permanent wiring. Lighting will be located at outside porches, hallways, baths, entrances, exits, and stairways.
	Passed Inspection Yes / No
	Re-Inspection Required Yes / No
	CEO
П	Date:

*.